

**Winchelsea New Hall**  
**EXTERIOR CONSULTATION**  
**Monday 6 June & Tuesday 7 June 2016**

Wheel chair escape route inadequate. The heating pipes sit on the floorboards with a hard cover and wheelchairs have to be negotiated over this awkwardly. In the event of a fire when people are stressed this would be hampering.

Bin area tidied up well, but needed greater clarification on rubbish disposal. Waterproof notices on inside and outside bins?

Car park extension done well, but not big enough for events and overspill around Winchelsea. Complaints about people's parking cutting up grass verges. Some people struggle to manoeuvre in the car park area.

Couple a disabled notice put by one or two spaces - one to the left of the front door? Ensure sufficient clearance for emergency escape route.

Outside of hall not lit when leaving in dark. Automatic light sensor.

Look at ways to slow traffic down for safe crossing.

eg. Zebra/pelican crossing. They must have lights now, which may cause light pollution for local people living nearby.

eg. Slower speed sign which can be switched on for events?

Decking too low. Should be level with door and the step down should be at the end towards the field.

**Potential Action Points**

1. Improve wheelchair escape route
2. Designate disabled parking space
3. Raise decking so it is level with the building threshold.
4. Information re: bin area.
5. Automatic light sensor